

## PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated: 24/01/2025

It is certified that an inspection team headed by .....

(Name of Officers with designation) from .....

(Name of Department/ Office) inspected the St. Anselm's School at Hadota, Sikar Bye Pass Chomu, Jaipur (Name & Address of the school) on ..... (date of inspection) and found that the St. Anselm's School ( Name of school) has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt. The above is valid for a period of ... Two year.....

Signature with Seal: कै सरी

Name

ग्राम पंचायत हादोता

Designation

पं. स. गोविन्दगढ़ (जयपुर)

Name &amp; Address of the Office / Department : .....

To

The Principal,  
St. Anselm's School,  
Hadota, Sikar bye pass, chomu, Jaipur

(Name &amp; Address of the Institution)

\* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.



OFFICE OF THE CHIEF CHEMIST  
PUBLIC HEALTH ENGINEERING DEPARTMENT, RAJASTHAN, JAIPUR

REPORT OF THE CHEMICAL EXAMINATION OF WATER

Report No.: Raj/DW(Chem)/2024-25/ 4841

Dated : 29/1/2025

Issued To,

Principal, St. Anselms Sr. Sec. School  
Hadota, Sikar Bye pass  
Chomu

The sample was not collected  
by this laboratory

Not Valid for Water  
Quality Legal Cases

District: Jaipur  
Block/City: Chomu

Ref_ID :	22	Lab Sample No. :	29
Reference : Your Letter No.:	10	Source :	TW
Reference Dated :	24-01-2025	Source Location :	St. Anselm s School, Hadota, Sikar Bye pass
Date of Receipt :	24-01-2025	Habitation/Ward No.:	Hadota
Name of Sample Taker : Melwyn Saldani		Village/Colony/Town :	Hadota
Desig. of Sample Taker :		Gram Panchayat/City Area :	Chomu
Latitude :		Date of Collection :	24-01-2025
Longitude :		Date of Examination :	28-01-2025
Elevation in Meter :			
IS-10500:2012			
Test Parameters	Requirement (Acceptable Limit)	Permissible limit in the absence of alternative sources	Test Values of Samples
1 pH	6.5 to 8.5	No. Relaxation	7.9
2 Turbidity(NTU)	1	5	Clear
3 Colour (Hazen Unit)	5	15	None
4 Odour	Unobjectionable	-	UO
5 Total Alkalinity (as CaCO <sub>3</sub> )	200	600	220
6 Total Hardness (as CaCO <sub>3</sub> )	300	600	100
7 Calcium (as Ca++)	75	200	16
8 Magnesium (as Mg++)	30	100	15
9 Chloride (as Cl <sup>-</sup> )	600	1000	50
10 Sulphate (as SO <sub>4</sub> <sup>-2</sup> )	200	400	10
11 Nitrates (as NO <sub>3</sub> <sup>-</sup> )	45	No. Relaxation	78
12 Fluoride (as F <sup>-</sup> )	1.0	1.50	0.87
13 Total Dissolved Solids	500	2000	560
14 Residual Chlorine	0.2	0.5	Nil

Note:- Report is not valid for Food Licence or any Certificate.

Superintending Chemist  
PHED, Lab, Jaipur

Dated:

Report No.: Raj/DW(Chem)/2024-25/

Copy to:

1. The Chief Chemist, Public Health Engineering Department, Rajasthan, Jaipur.

0

Superintending Chemist